

INSTALLATION INSTRUCTIONS

TEMPORARY LED STRING LIGHTS

2 YEAR LIMITED PRODUCT WARRANTY

Visit www.els-led.com for warranty for details
For support contact support@els-led.com

MODELS

Model	Lumens	Wattage	Max Link Qty (18/2 AWG)
TSLED-130W-2P100	16000	130	3
TSLED-100W-2P100	12000	100	4
TSLED-50W-2P50	6000	50	8



APPLICATION & WARNING

- Suitable for Construction Sites or locations requiring temporary lighting.
- Not Suitable for Use on Dimmers
- The LED String Light must be installed in an appropriate environment. Keep away from corrosive substances. Operating in extreme harsh environments may shorten life.
- Allow lamp/fixture to cool prior to handling. Avoid direct eye exposure!
- Keep combustibles that can burn away from light.

INSTALLATION

- Prior to Installation and Maintenance of the light, disconnect the power to prevent electric shock
- Remove Product From packaging, inspect for damage or other defects.
- Install product with the included hook onto a suitable structure
- After installation power the String light to verify operation
- Follow Max link requirements for connection additional string lights end to end.
- Ensure that String light is secured in place to prevent workplace injury.

INSTALLATION



LINKABLE



ELEVATE
LIGHTING SOLUTIONS

📍 1000 Commerce Center Dr, Elkton MD 21921

🌐 els-led.com



(718).338.1851

Fax: (718).228.1851



Support@ELS-LED.com



orders@els-led.com